Inspectorate America, Corp. 178 Mortland Road Searsport, Maine 04974 (207)548-6440





INSPECTORATE

QUALITY CERTIFICATE

Vessel SHORE TANK NO. 4
Customer SPRAGUE
Operation ANALYSIS

Port SEARSPORT, MAINE
Date January 17, 2006
Terminal SPRAGUE

Report SP/06/0115 Reference V-06-00010 Sample # 239365

Name of material being tested Description of sample source Samples Drawn by (company) Samples Tested by (company) NO. 6 FUEL OIL 2.0%

EX. SHORE TK NO. 4 AFTER DISCHARGE OF PSARA INSPECTORATE INSPECTORATE

Tests being Performed	Test method	Minimum	Maximum	Sample Source
GRAVITY, API @ 60 F	ASTM D 4052 ASTM D 93			10.7 198
FLASH POINT, F VISCOSITY, SSF @ 122 F	ASTM D 445/2161			225
POUR POINT, F	ASTM D 97			+10.4
WATER & SEDIMENT, % VOL.	ASTM D 1796			0.05
SULPHUR, % WT.	ASTM D 4294			1.85 0.040
3H, % WT.	ASTM D 482 AA/AE			80
JANADIUM, PPM SODIUM, PPM	AA/AE			10
BTU'S/POUND	CALCULATION			18,291
BTU'S/GALLON	CONVERSION			151,578
NITROGEN, % WT.	ASTM D 5762			0.4576
CARBON RESIDUE, % WT.	ASTM D 4530			13.93 5.54
ASPHALTENES, % WT.	IP-143			J.J4
SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON				
A COMPOSITE BASIS IN SPRAGUES TERMINAL SHORE TANK AS NOTED ON THE				
CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED F PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PROD				
BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARF	RANTY OF			
MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE				
AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY F	OR CLAIMS OR LOSSES			
THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTIC	ON REPORT/ANALYSIS.			

DENNIS E. CURTIS

Inspectorate America Corp (Searsport, Me.)